



Hearing Loops

DIVISION 27: Communications & Technology

Part 49: General

49.03 COORDINATION

D. In any space over 1,000 square feet that is open for public meeting and wired with a public address system, a review should be completed to see if hearing loops should be added to the scope of the project. If loops are needed, an outside contractor will be brought in by the design team and/or general contractor for the design and installation.

Building Design & Construction Standards, page 396

October 1, 2013

Edited: February 5, 2019

<https://www.fcgov.com/opserv/pdf/building-design-standards.pdf?1554850706>